



Connection Impact Assessment (CIA) Application

Planning & Engineering | cnppanning2@cnpower.com | 905-871-0330

Validate Form
Clear Form

▶ ABOUT THIS FORM

This Connection Impact Assessment (CIA) application is to be completed by any proponent interested in connecting a Distributed Energy Resources (DER) with a project size over 10 kilowatts (kW) to Cornwall Electric (CE). This includes DER applying for a new CIA or for revision(s) to their original CIA. This form expresses an intent to enter into an agreement between CE and the customer (or host customer* for load displacement projects) for completion of a CIA associated with connecting a DER to the CE distribution grid. The CIA Application shall be part of the required servicing (electrical installation, maintenance, and operating) agreements between CE and the proponent. Through this process, CE will be the proponent's contact with other Governing Authorities.

*For Load Displacement projects, the term "host customer" refers to the owner of the load facility. The term "DER owner" refers to the owner of the DER facility.

▶ TECHNICAL REQUIREMENTS

For technical requirements of CE's DER projects, refer to the "DER Technical Interconnection Requirements Interconnections at Voltages 50kV and Below", please contact ceengineering@cornwallelectric.com

▶ SUBMISSION INSTRUCTIONS

Please return the completed form, fees, and other required documents by mail to:

Cornwall Electric
Attn: Planning & Engineering
Generation Connection Application
1001 Sydney St.
Cornwall, ON, K6H 3K1

▶ IMPORTANT NOTES

- An engineering stamp and all red box fields (on electronic version of form) are mandatory. Incomplete applications may be returned by CE and will result in delays in processing your application. Click the "Validate Form" button on the top right of this page to ensure all required information is filled. If any of the required fields are not applicable to your project, type "N/A" in any required text field or "0" in any required numerical field
- API specific requirements and notes are found in Sections S and T, respectively
- Applicants are cautioned NOT to incur major expenses until CE approves to connect the proposed DER facility.
- All technical submissions (CIA Application, Single Line Diagrams, etc.) must be signed, dated and sealed by a licensed Ontario Professional Engineer (P.Eng.).
- The proponent will pay for the CIA according to the CE CIA Fee Schedule.





The siting restrictions in O. Reg. 274/18 which were administered by electricity distributors such as CE have been replaced by amendments to the Planning Act (Ontario) that puts siting and planning requirements for renewable DER facilities under municipal oversight. It is recommended that you discuss municipal permitting and approvals requirements with the planning department in the municipality where your DER project is located before you proceed.

SECTION A: APPLICATION INFORMATION

Engineering Stamp

Application Type *choose one*

Capacity Increase Request

Date *mm/dd/yyyy*Program Type/Purpose *choose one*

Load Displacement

Program Type (additional details)

Project Name

Ontario Corporate Number or Business Identification Number

Proposed In Service Date *mm/dd/yyyy**If this project is a subdivision project, please complete the following fields:*

Subdivision Project Name

Number of Lots

*For certain application type selections, please complete the required fields:*Original CIA Project ID # *xx,xxx*Revised Fields *list the fields that have changed from your previous application*

SECTION B: PROJECT LOCATION

Address

City / Town / Township

Postal Code

Lot Number(s)

Concession Number(s)





SECTION C: CONTACT INFORMATION

CIA will be issued in the name of the host customer (load facility owner). All agreements (including CCA and DCA) are only made between CE and the host customer. This section is strictly to gather contact information of some of the key contacts that are involved with the project.

Who is the single point of contact for this project?

☐ Host Customer ☐ DER Owner (if different from host customer) ☐ Consultant

Please enter the following information about the host customer (load facility owner)

Contact Person

Company's Legal Name

Mailing Address including postal code, P.O. Boxes and Rural Routes will not be accepted

Work Telephone

Cell Phone

Fax Number

Email Address

Please enter the following information about the DER owner (if different from host customer)

Contact Person

Company's Legal Name

Mailing Address including postal code, P.O. Boxes and Rural Routes will not be accepted

Work Telephone

Cell Phone

Fax Number

Email Address

Please enter the following information about the consultant

Contact Person

Company's Legal Name

Mailing Address including postal code, P.O. Boxes and Rural Routes will not be accepted

Work Telephone

Cell Phone

Fax Number

Email Address





▶ **SECTION D: CUSTOMER STATUS**

Is there an existing CE account at the project location?

☐ Yes ☐ No

Is the account holder aware of this application?

☐ Yes ☐ No

Does your account fall within a residential-rate classification?

☐ Yes ☐ No ☐ Do not Know

Existing Account Number

Account Holder Name

Does the account holder have an HST registration number?

☐ Yes ☐ No

HST Number

▶ **SECTION E: EXISTING DER**

Are there existing DER at the point of common coupling (PCC)?

☐ Yes ☐ No

Existing Project Number

Existing Project Size (kW)

Program Type For Existing DER *choose one*

DER type: ☐ Synchronous ☐ Induction ☐ Inverter based ☐ Other

For synchronous units	For induction units	For inverter based units
Min. power limit for stable operation <i>kW</i> <input type="text"/>	Direct axis sub-transient reactance, X''_d <i>pu</i> <input type="text"/>	Inverter rating <i>kVA</i> <input type="text"/>
Direct axis sub-transient reactance, X''_d <i>pu</i> <input type="text"/>	Direct axis transient reactance, X'_d <i>pu</i> <input type="text"/>	Maximum continuous power output <i>kW</i> <input type="text"/>
Direct axis transient reactance, X'_d <i>pu</i> <input type="text"/>	Total PF correction installed <i>kVAR</i> <input type="text"/>	
Direct axis synchronous reactance, X_d <i>pu</i> <input type="text"/>		
Zero sequence reactance, X_0 <i>pu</i> <input type="text"/>		





SECTION F: PROJECT INFORMATION

Station Name *(optional to leave blank for behind the meter projects)*

Feeder *(optional to leave blank for behind the meter projects)*

Feeder Voltage (kV) *(optional to leave blank for behind the meter projects)*

Project Size (kW) *total maximum output capacity*

Equipment Capacity (kVA) *total equipment nameplate rating*

Type of Connection

☐ Single Phase ☐ Three Phase

If this is a solar project, please answer the following questions:

Mounting Type *select one*

If this is a water project, please answer the following questions:

Is your generation facility located on provincial Crown or federally-regulated lands?

☐ Yes ☐ No

Is water your primary energy source?

☐ Yes ☐ No

Fuel/Energy Type *select all that apply*

- ☐ Solar (PV)
- ☐ Wind
- ☐ Water
- ☐ Natural Gas
- ☐ Biogas
- ☐ Biomass
- ☐ Diesel
- ☐ Battery Energy Storage System
- ☐ UPS
- ☐ CHP/Co-gen
- ☐ Other (specify below)

SECTION G: STATION SERVICE LOAD INFORMATION

The host customer's station service load details

If there is an existing account at the project location, populating the fields in Section G is required for CE. Ensure selection below matches with this note.

☐ Required ☐ Optional

Maximum Demand of Station Service Load of DER *kW*

Average Monthly Consumption *kWh*





SECTION H: CONNECTION INFORMATION

Provide location or a site plan of the generation facility with proposed line routings for connection to CE's distribution system. It should identify the Point of Expansion (POE), the Point of Common Coupling (PCC), the location of the generation facility, and (if applicable) the route of the new line between the generation facility and the POE (ie. on private property or public road/right-of-way). This is not required for existing load customers that are connecting a load displacement generation, net metering generation or energy storage system behind their existing metered connection point. Please see "Appendix A" for a visual representation of POE and PCC

DOM Drawing/Sketch Number

DOM Revision Number

Please provide an SLD of the Generator's facilities, including the PCC, transformer and connecting station, feeder, and supply voltage.

SLD Drawing/Sketch Number

SLD Revision Number

POE Latitude *degree decimal format*

POE Longitude *degree decimal format*

PCC Latitude *degree decimal format*

PCC Longitude *degree decimal format*

Generation Facility Latitude *degree decimal format*

Generation Facility Longitude *degree decimal format*

Length of Line from POE to PCC *km*

Length of Line from PCC to Generation Facility *km*

Important: The line between the PCC and the Generation Facility must NOT be shared with any other DER owner (refer to Appendix A).

Conductor Type/Size *for the line between the PCC and the Generation Facility*

Generator Fault Contribution *with fault location at the PCC*

IMPORTANT NOTES:

If this project requires line expansion work between the POE and PCC, CE will provide a cost estimate to construct any line located on public road right-of-way. The cost estimate will include a breakdown of uncontested work (i.e. overbuild to existing line) that can only be performed by CE, as well as contestable work (i.e. new construction/green-field) that may be performed by the Generator, their contractor or CE. The design of uncontested and contestable work shall conform to CE specifications).

For Generator-owned line, the Generator may apply to construct the line on existing CE-owned poles. This is known as an application for Joint Use (JU) of poles. If the application is accepted, CE will provide the Generator with information on initial connection costs, annual pole-space rental and emergency service (ES) fees, and required JU & ES Agreements.





▶ SECTION I: ENERGY STORAGE OR UPS

Please complete the following section if your project includes energy storage.

Number of Units

Inverter Unit Size enter zero if inverter is shared with generation unit(s)

Energy Storage Unit Size kWh

Total Energy Storage Size kWh

Energy Storage Facility Control Strategy

- ☐ Peak Shaving
- ☐ Dynamic VAR Support
- ☐ Frequency Support
- ☐ Other

Please submit a detailed description of the control strategy according to the templates in Appendix B. CE reserves the right to modify the control strategy as part of its Detailed Technical Connection Assessment.

▶ SECTION J: LOAD DISPLACEMENT/PEAK SHAVING

Please complete the following section if this is a load displacement or peak shaving project

Operating Mode

- ☐ Parallel ☐ Non-Parallel

Transition Type

- ☐ Closed "make before break" ☐ Open "break before make"

Time that generator remains parallel to grid closed transition only, ms

For non-parallel load displacement, SCADA monitoring and Gross Load Billing (GLB) may apply. For load displacement generation facilities, please attach a schedule of the forecasted maximum generation output (as a function of loading of the facility). At a minimum, include the forecasted generation output information (i.e. Watts and VARs) during the minimum and maximum of the load facility to which the load displacement generator is connecting (see Appendix C for template)





SECTION K: DER CHARACTERISTICS (1/1)

For facilities with multiple generators: If your generators have different characteristics, please use the "Add Page" button and provide the characteristics for each generator on the additional pages.

DER type: ☐ Synchronous ☒ Induction ☐ Inverter based ☐ Other

Number of Generating Units

Rated Capacity of Each Unit

 kW

kVA

DER Output Voltage in kV

Manufacturer

Type or Model Number

If Power Conversion Type is "Other", please provide values equivalent to a Synchronous or Induction type generator.

Maximum Starting In-rush Current multiple of full load current, pu

Generator Winding Connection

☐ Delta ☐ Star

Neutral Grounding Method for star winding connection only

☐ Solid ☐ Ungrounded ☐ Impedance

Impedance R in ohms

Impedance X in ohms

Limits of range of reactive power at the machine output:

Lagging over-excited, kVAR

Lagging Power Factor

Leading under-excited, kVAR

Leading Power Factor

Limits of range of reactive power at the PCC:

Lagging over-excited, kVAR

Lagging Power Factor

Leading under-excited, kVAR

Leading Power Factor

For synchronous units

Nominal Machine Voltage kV (LL)

Unsaturated Reactance kVA Base

Unsaturated Reactance kV Base

Direct Axis Subtransient Reactance, Xd'' pu

Direct Axis Transient Reactance, Xd' pu

Direct Axis Synchronous Reactance, Xd pu

Subtransient Time, Td'' ms

Zero Sequence Reactance, X0 pu

For induction units

Nominal Machine Voltage kV (LL)

Unsaturated Reactance kVA Base

Unsaturated Reactance kV Base

Direct Axis Subtransient Reactance, Xd'' pu

Add Page





SECTION L: INTERFACE TRANSFORMER

The transformer connecting to the CE distribution system

Transformer Ownership

☐ Customer ☒ CE

Transformer Rating *kVA*

Transformer Type

☐ Single Phase ☐ Three Phase

Nominal Voltage of High Voltage Winding *kV*

Nominal Voltage of Low Voltage Winding *kV*

Impedance Base (if different than ratings above)

kVA Base kV Base

Impedance (R) *pu*

Impedance (X) *pu*

OR

Impedance (Z%) %

High Voltage Winding Connection

☐ Delta ☐ Star

High Voltage Grounding Method *for star winding connection only*

☐ Solid ☐ Ungrounded ☐ Impedance

Star Impedance R *in ohms*

Star Impedance X *in ohms*

Low Voltage Winding Connection

☐ Delta ☐ Star

Low Voltage Grounding Method *for star winding connection only*

☐ Solid ☐ Ungrounded ☐ Impedance

Star Impedance R *in ohms*

Star Impedance X *in ohms*

Notes

The term "High Voltage" refers to the connection voltage to CE's distribution system and "Low Voltage" refers to the generation or any other intermediate voltage.

Providing a photo of transformer equipment along with this application may help expedite your application.





SECTION M: INTERMEDIATE TRANSFORMER

Transformer between the interface transformer and DER

Please complete the following section if your project includes an intermediate transformer. Do

you intend to install an intermediate transformer?

☐ Yes ☐ No

Transformer Rating kVA

Transformer Type

☐ Single Phase ☐ Three Phase

Nominal Voltage of High Voltage Winding kV

Nominal Voltage of Low Voltage Winding kV

Impedance

<input type="text"/>	kVA Base	<input type="text"/>	kV Base
----------------------	----------	----------------------	---------

Impedance R pu

Impedance X pu

High Voltage Winding Connection

☐ Delta ☐ Star

High Voltage Grounding Method for star winding connection only

☐ Solid ☐ Ungrounded ☐ Impedance

Star Impedance R in ohms

Star Impedance X in ohms

Low Voltage Winding Connection

☐ Delta ☐ Star

Low Voltage Grounding Method for star winding connection only

☐ Solid ☐ Ungrounded ☐ Impedance

Star Impedance R in ohms

Star Impedance X in ohms

Notes:

The term "High Voltage" refers to the connection voltage to CE's distribution system and "Low Voltage" refers to the generation or any other intermediate voltage.

SECTION N: HIGH-VOLTAGE GROUNDING TRANSFORMER

Please complete the following section if your project includes a high-voltage grounding transformer.

Do you have a high-voltage grounding transformer?

☐ Yes ☐ No

Transformer Type select one

☐ Zig-Zag ☐ Star-Delta

Zero Sequence Impedance (Z0) R ohms

Zero Sequence Impedance (Z0) X ohms





▶ SECTION O: SUBMISSION CHECKLIST

Please ensure the following items are completed prior to submission. Your application may not be processed if any part is omitted or incomplete:

- ☐ Payment in full including applicable taxes (by cheque payable to “Cornwall Electric.”)
- ☐ Completed Form B stamped by a Professional Engineer
- ☐ Signed Study Agreement (original signature is required)
- ☐ Single Line Diagram (SLD) of the Generator’s facilities, must be stamped by a Professional Engineer
- ☐ Protection Philosophy
- ☐ Distribution Operating Map (DOM) and/or Site Plan (not required for existing load customers that are connecting a load displacement generation, net metering generation or energy storage system behind their existing metered connection point)
- ☐ Load Displacement Generation Facility’s load and generation schedules (if applicable)
- ☐ Load Displacement Generation Facility’s mode of operation (if applicable)
- ☐ Energy Storage Facility operating strategy description and parameters (if applicable)
- ☐ Emergency Backup Generation Facility’s mode of operation (if applicable)

▶ SECTION P: CIA APPLICATION FEE CHECKLIST

Please ensure the following items are completed prior to submission. Your application will not be processed if any part is omitted or incomplete. Check all that apply:

- ☐ Applicable CIA Fee
See the [Connection Impact Assessment Fee Schedule](#) on our website for costs. Please enter the amount from the fee schedule. \$ +HST
- ☐ Transmission Customer Impact Assessment (TxCIA) Fee (if applicable)
A TxCIA is also required if the total nameplate generation of the project is greater than 10MW. \$ +HST





▶ **SECTION Q: ATTACHMENTS**

Attached Documents / Drawings

Item #	Description	Document #	# of Pages
1			
2			
3			
4			
5			
6			

▶ **SECTION R: NOTES**





▶ SECTION S: CE Specific Required Fields

This section contains specific information that is required by CE. Please read Section T notes regarding this section if you need further details.

What is the barcode of the nearest pole serving the project location?

CE Account Number *if transformer is owned by CE*

▶ SECTION T: CE Specific Additional Notes

Section A: no additional notes

Section B: no additional notes

Section C: no additional notes

Section D: no additional notes

Section E: no additional notes

Section F: no additional notes

Section G: no additional notes

Section H: no additional notes

Section I: no additional notes

Section J: no additional notes

Section K: no additional notes

Section L: At the Generator's expense, and if requested, CE may provide transformation up to a maximum of 500 kVA three-phase, as described in the CE Conditions of Service.

Section M: no additional notes

Section N: no additional notes

Section O: for new DER site, Distribution Operating Map (DOM) is required by CE in addition to Site Plan

Section P: When there is an upstream LDC, an additional fee will be required for costs associated with this LDC's CIA.

Section Q: no additional notes

Section R: no additional notes

Section S: - For question: "What is the barcode of the nearest pole serving the project location?", this is only applicable if you choose "No" to question: "Is there an existing CE account at the project location?" in Section D


- For question: "CE Account Number (if transformer is owned by CE)", this is only applicable if you answer "CE" to question: "Transformer Ownership" in Section L.





► APPENDIX A - FIGURES & DIAGRAMS


Figure A1: Where There is No New CE Owned Line Expansion



*PCC: the point where the customer facility connects to the LDC owned system

**PODC: the point where the DER unit(s)'s interconnection system connects the DER unit(s) to the DER facility.

Figure A2: Where There is a New CE Owned Line Expansion





► APPENDIX B - MINIMUM CONTROL STRATEGY INFORMATION FOR ENERGY STORAGE FACILITIES OR OTHER TECHNOLOGIES

Figure B1: Peak Shaving

Peak Shaving			
Description of Control Strategy			
When Operating as a Load			
Switch In Time	Switch Out Time	Load kW (peak)	Load kVAR (peak, leading/lagging)
When Operating as a Generator			
Switch In Time	Switch Out Time	Generation kW (peak)	Generation kVAR (peak, leading/lagging)

Figure B2: Dynamic VAR Support

Dynamic VAR Support			
Description of Control Strategy			
Switch In Condition	Switch Out Condition	Generation kW (peak)	Generation kVAR (peak, leading/lagging)

Figure B3: Frequency Support

Frequency Support			
Description of Control Strategy			
Switch In Condition	Switch Out Condition	Generation kW (peak)	Generation kVAR (peak, leading/lagging)

Figure B4: Other Control Strategies

Other	
Description of Control Strategy and Relevant Operating Parameters	





► **APPENDIX C - LOAD DISPLACEMENT FIGURES**

Figure C1: Example Schedule With Minimum Information Required for Load Displacement Projects

	Load of Facility (kW)	Load of Facility (kVAR, lead or lag)	Generation Output (kW)	Generation Output (kVAR, lead or lag)
Minimum Load				
Maximum Load				

